# lonpro™



# 

#### Reverse Osmosis & EDI for pharmaceutical industry applications

lonpro<sup>™</sup> packaged systems produces Purified Water (PW) in line to current Pharmacopoeia (USP, Ph Eur and JP). The lonpro<sup>™</sup> systems are skid-mounted sytems, Plug & play, FAT tested and chemically sanitisable.



#### **HYDREX® CHEMICALS**

Hydrex® 4000 water treatment chemicals from Veolia Water Technologies should be used for optimized plant operation.

#### **ASSOCIATED SERVICES**

Local aftermarket service and support teams offer preventative and corrective maintenance programs to ensure the long-term, efficient operation of installed plant.



# **System Operating Parameters**

Model	Unit	500	750	1000
EDI Product Flowrate	m³/h	0.50	0.75	1.00
Nominal Feed Flowrate	m³/h	0.70	1.03	1.37
Global Recovery	%	70-75		
Typical Design Flux	l/h/m²	26	32.4	31.5
Typical Salt Rejection	%	RO >96%   EDI >99%		

# System Dimensions<sup>(1)</sup>

Model	Unit	500	750	1000
Total Installed Length	m	1.61		
Total Installed Width	m	0.87		
Total Installed Height	m	1.61		
Empty Weight	kg	600 approx		
Operating Weight	kg	1000 approx		

<sup>(1)</sup> Not utilities nor options included.

# **Pipes Connections**

Model	Unit	500	750	1000
Feed	DN	20		
Treated water <sup>(2)</sup>	DN	20   3/4"		
Drain	DN	32		

<sup>(2)</sup> PVC Socket Union | Stainless steel tri-clamp

## **Materials of Construction**

Softeners	Composite resin		
Soft Water Tank	High Density Polyethylene		
Skid	Aluminium		
Control Cabinet	Painted Mild Steel		
Low pressure Pipework	PVC PN16 as a base - Option for Stainless Steel product outlet (ASME BPE SF1)		
HIgh pressure Pipework	ISO 1127 (serie 1) 316 Stainless Steel		

# **Power Requirements**

Parameter	Unit	Value
Voltage	V	3 x 380/480 V + Earth
Frequency	Hz	50/60
Phases	-	3





#### **Environmental Conditions**

Parameter	Unit	Value
Minimum ambient temperature	°C	5
Maximum ambient temperature	°C	35
Maximum humidity	%	90

#### Feed water Requirements<sup>(3)</sup>

Surface water or well water - WHO drinking water specification

Parameter	Unit	Value
Minimum water temperature	°C	5 (7)
Maximum water temperature	°C	25 (8)
Minimum supply pressure	barg	3
Maximum supply pressure	barg	6
Max inlet Iron Fe³⁺	mg/l	< 0.05
Max inlet Manganese Mn <sup>2+</sup>	mg/l	< 0.05
Max Silt Density Index (SDI)	-	< 3
Maximum Inlet Turbidity	NTU	< 1
Maximum Inlet TDS	mg/l	up to 1000
Max inlet Total Hardness	mg/l CaCO₃	< 400
Max inlet CO <sub>2</sub>	mg/l	< 30 (4)
Max inlet Silica	mg/l	< 20
Max inlet TOC	mg/l	< 1
Max inlet Free Chlorine Cl <sub>2</sub>	mg/l	< 0.2

<sup>(3)</sup> Process calculations for RO, degasser and EDI must be performed by BU based on specific water analysis and project data <sup>(4)</sup> For CO<sub>2</sub> membrane removal option

<sup>(7)</sup> At low temperature, HP pump might need to be redesigned to comply with requirements

<sup>(8)</sup> At high temperature, performance must be evaluated precisely to ensure quality of produced water

#### **Typical Treated Water Quality**

Parameter	Unit	Value
Average Conductivity	μS/cm	< 0.2 µS/cm (5)
Maximum Conductivity	μS/cm	< 1.3 µs/cm @25°C
Bacteria	cfu/100 ml	100   10 <sup>(6)</sup>

<sup>(5)</sup> at design conditions (500 ppm feed TDS, 15°C and 1 bar outlet pressure)

<sup>(6)</sup> without product outlet UV | with product outlet UV



Designed and Manufactured by Solys Veolia www.veoliawatertechnologies.com

BUREAU VERITAS